

From: Laura Gullledge [mailto:llgtec@hotmail.com]

Sent: Sunday, June 27, 2010 11:42 AM

To: Jrushin; Reggie12-08 Atkinson; Reggie&Loretta Atkinson; Chris Jarvis; dave@local-notes.com; Andrew and Kristen Rushin; Robbie-4-22-08 Atkinson

Cc: Laura Gullledge

Subject: Beach House HVAC Condensate

Our HVAC upstairs unit has a tendency to collect junk in the condensate line and then overflow. There are two lines running outside. The top line is the normal condensate line and it should have water flowing from this when the unit is running. If it is plugged, water would be coming out of the bottom pipe (Emergency Line). If that happens, we need to know about it to get the line unplugged. If it goes on for a while, it ends up staining our ceiling. Perry has labeled the outside pipes to help us.

Thanks for helping to keep an eye on this.

Laura

